



RFDS 6.00 HOOD & DUCT EXTINGUISHING SYSTEMS

Hood and duct extinguishing systems shall be monitored by a separate zone on the fire alarm control panel and at the central station.